



RURAL ELECTRIFICATION AND RENEWABLE ENERGY CORPORATION

Clarification 002

The following clarification were sought by a bidder for **RFx 100000862: SOLAR FOR SCHOOLS MAINTENANCE CONTRACTORS – FRAME CONTRACT.** and clarified as follows;

No.	Bidder's Query	Clarification
1	If a lot has 2 counties do we take the total cost of one and multiply by two to get the totals for that particular lot. Example is Lot 3	No – Provide the total per lot

Technical Specifications for Equipment and Accessories

A. Inverters – 1000W / 1500W

	REREC Requirement		Bidder's Query	Clarification
9	Battery low shut down	(10.5+/-0.5) VDC	Clarification of whether the system voltage is 12Vdc or 24Vdc as indicated on item number 6 (inverter nominal voltage)	This parameter is corrected to (21+/-0.5) VDC This is a 24Vdc system

B. Inverter – 4,000W

	REREC Requirement		Bidder Query	Clarification
6	Rated Continuous Output power –	3,000W Pure sine wave for Power Inverter	Clarification between minimum rated output power and rated output power as indicated on item number 3&10	This is ok
13	Battery low shut down	(20.5+/-0.5) VDC	Clarification of whether the system voltage is 24Vdc or 48Vdc as indicated on item number 6 (inverter nominal voltage)	This parameter is corrected to (42+/-0.5) VDC This is a 48Vdc system
14	Low voltage battery recover	21VDC		Clarified to 49.6Vdc
15	High battery voltage cutoff	30VDC		Clarified to 60Vdc